FIRE AND RESCUE SERVICE STATION MYLAPORE, CHENNAI-600 004

SL.NO: 21/ V / MYL /2025

DATE: 19.02.2025

REG NO: 21/ V /MYL/2025

NO OBJECTION CERTIFICATE

SUBJECT:

Fire And Rescue Services - Mylapore Fire And Rescue Service

Station - No Objection certificate building/To erect A school

building/ Issue school Recognition - Reg.

NOTICE:

1. Govt - Order No: 122 School Education (2) Department

Date.14.09.2014

2. Govt - Order No:123 School Education (2) Department

Date.14.09.2014

Application received from principal, M.CT.M.CHIDAMBARAM CHETTYAR SCHOOL

As Per the Govt Order and the Application, M.CT.M.CHIDAMBARAM CHETTYAR SCHOOL Situated at NO:179, LUZ CHURCH ROAD, MYLAPORE, CHENNAI – 600 004 was Inspected by the Station Officer Mr.R.Arokiasamy on 18-02-2025. There is No Objection from the Department of Fire & Rescue Services a School Building at this place or to Issue School Recognition. (NOC Period Time 19.02.2025 to 18.02.2026)

CONDITIONS

- 1. This NOC is valid for one year from the date of issue.
- 2. All the extinguishers have to be recharged and maintained periodically as per code in 2190.
- 3. Fire & Safety system arrangement have to be provided in accordance with to requirement of NBC part IV Fire & Life safety 2000

4. This NOC is not applicable for swimming pool

FIRE AND RESCUE SERVICE STATION MYLAPORE, CHENNAI- 600 004.

MYLAPORE, CHE

PRINCIPAL,

M/S.M.CT.M.CHIDAMBARAM CHETTYAR SCHOOL,

NO:179, LUZ CHURCH ROAD,

MYLAPORE, CHENNAI - 600 004.

COPY:

TO

1. District Officer, Chennai City South, Ashok nagar,